

# KENYA ELECTRICITY GENERATING COMPANY LIMITED

## TENDER KIP- 16/2010 TO SUPPLY OF GENERATOR TRANSFORMERS FOR SEVEN FORKS POWER STATIONS.

### ADDENDUM NO. 2

#### SECTION E Technical specifications schedule of requirements

#### PRICE SCHEDULE FOR ALL TRANSFORMERS

The price schedule tables for each transformer as given on pages 44, 62, 81, 92, 104. For overseas suppliers, the Total cost & freight (CFR) is **Mombasa Port and NOT Nairobi port** as indicated.

#### COOLING SYSTEM FOR KIPEVU AND TURKWEL TRANSFORMERS

PAGE No	CLAUSE	DESCRIPTION	CHANGE
25 62	2 32	ODAF ODAF	Change the required cooling from ODAF to ONAN/ONAF and given MVA rating of 40MVA is ONAF rating. ONAN rating is 32.5MVA
25 81	3 40	ODAF ODAF	Change the required cooling from ODAF to ONAN/ONAF and given MVA rating of 60MVA is ONAF rating. ONAN rating is 42MVA

**Therefore requirement for the transformers for Kipevu and Turkwel power stations is ONAN/ONAF cooling**

#### ACKNOWLEDGEMENT OF ADDENDUM NO.2

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in Addendum has been incorporated in the tender proposal.

Signed .....

Tenderer: .....