

26th July 2017

TENDER FOR RELOCATION OF ONE GE FRAME 6 GAS TURBINE FROM EMBAKASI IN NAIROBI TO MUHORONI: KGN-GT-12-2017

KenGen wishes to make additional changes to above tender through addendum 3 below

No.	Proposed Changes	Effective Changes
1	Additional Scope	Painting of 1 million litres tank at Muhoroni after assembly. Details below
2	Health, Safety and Environment Issues	To make good the Embakasi site after dismantling of the turbine and associated equipment. Details below
3	Price Schedule	The bidder to take note of the changes as a result of 1& 2 above and reflect them in the price schedules and tender forms

4. All the other terms and conditions remain unchanged

1. PAINTING OF 1 MILLION LITRES FUEL TANK TO BE TRANSFERRED TO MUHORONI

ITEM	DESCRIPTION	UNIT	QUANTITY	RATE	AMOUNT
3.16	i) Provide tools, materials and equipment to carry out external and internal Surface preparation of the tank in readiness for painting. Use relevant Kenya standard	SUM			
	ii) Supply alluminium based paints and provide tools, materials and equipment for application of the paints Use relevant Kenya standard	SUM			
	iii) Carry out hydro-test and calibration of the tanks Use the relevant standard approved by Employer	SUM			

TOTAL COST TRANSFERRED TO PRICE SCHEDULE 3	
---	--

2. HEALTH, SAFETY AND ENVIRONMENT

ITEM	DESCRIPTION	UNIT	QUANTITY	RATE	AMOUNT
3.17	i) All Scrap generated from the dismantling activities to be transferred to Employer designated scrap area. All cable trenches to be covered with existing slabs after recovery of HV, MV and LV cables.	SUM			
	ii) Recover fuel pipes from the day tanks to the two (2) fuel forwarding skids. Backfill the open trenches after recovery of the fuel pipes.	SUM			
	iii) Remove and dispose any contaminated ballast around the Gas turbines area. This should include the area around the foundation of the Gas turbine already relocated to Muhoroni.	SUM			
TOTAL COST TRANSFERRED TO PRICE SCHEDULE 3					

ACKNOWLEDGEMENT OF ADDENDUM 3

We/I, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....