



1st October 2018

TENDER FOR SUPPLY OF ENGINE COOLING CHEMICAL FOR KIPEVU POWER STATION KGN-KIP-011-2018

ADDENDUM NO.2

In accordance with the tender for **TENDER FOR SUPPLY OF ENGINE COOLING CHEMICAL FOR KIPEVU POWER STATION KenGen** hereby wishes to issue Clarification No. 2 as follows,

NO	BIDDERS CLARIFICATION	KENGEN RESPONSE
1.	The Nitrite substance is TOXIC .Can we have a chemical with zero concentration of the nitrite. If we bring a cooling chemical which has better performance but the chemical base is not nitrite and the dosing is higher will it be ok?	The equipment manufacturers recommend nitrite based inhibitor we cannot therefore accept anything less.
2	Is engine cooling chemical nafleet ewt liquid 9-108 available in Kenya? If available can you give directions on where it's found?	Sourcing is a responsibility of the bidder, KenGen cannot source for the bidders and again come back to buy from them.
3	This product is not locally stocked. Hence clarify the requirement to present a recent certificate from KEBS. Are other international laboratory certificates acceptable?	Certificates from other laboratories not acceptable. KEBS is Nationally renowned product quality certification organization in Kenya.
4	In order to commit to price and delivery, can we have quantity and frequency of orders?	Product supply is on when and if required basis. This will mostly be dedicated by the dispatch regime of Thermal power from Kipevu 1. However the 1st 6500litres are guaranteed.
5	Section IV 3.7.6 requires a one year warranty on this product. Kindly clarify this requirement since the product is a consumable.	since we are asking for KEBS certificate we could consider waiving the 1 year warranty

ACKNOWLEDGEMENT OF CLARIFICATION NO.2

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....