



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KGN-GDD-078-2017

TENDER FOR SUPPLY OF THROTTLING VALVES AND FLANGED TEE-PIECES
FOR GEOTHERMAL DEVELOPMENT DIVISION

Date: 21st August 2017

CLARIFICATION No. 3

In accordance with the tender for supply of **Throttling Valves and Flanged Tee-Pieces** for Geothermal Development Division, KenGen hereby issues Clarification.

No.	BIDDER'S QUESTION	KENGEN'S RESPONSE
1.	Specifically for the throttle valve - what is the required flow rate ?	In geothermal wells, the flow is not constant. Kindly supply as per tender specifications
2.	What is the thickness requirement for the flanged tees ?	All dimensions follow API standard for the specified class (900) - 10" ANSI 900 End Connection - RTJ Flanged, full face, type 6B

ACKNOWLEDGEMENT OF CLARIFICATION No. 3

We, the undersigned hereby certify that the Clarification is an integral part of the document and the alterations set out in Clarification has been incorporated in the tender proposal.

Signed _____

Tenderer _____

Date: