



# KenGen

## KENYA ELECTRICITY GENERATING COMPANY LIMITED

### TENDER FOR SUPPLY OF GEOTHERMAL WELLHEAD EQUIPMENT (Master Valves and Adaptor Flanges) – KGN-GDD-108-2017

#### CLARIFICATION NO.1

In accordance with the tender for supply of geothermal wellhead equipment (master valves and adaptor flanges), Item 2: Adaptor flanges, KenGen hereby issues clarification no.1.

	<b>CLARIFICATION SOUGHT</b>	<b>KENGEN'S RESPONSE</b>
1	For the tender KGN-GDD-108-2017,  ITEM 2: ADAPTOR FLANGES  Clarify definition of "erosion shield" for the Adaptor Flange. Unfamiliar with a 4" weld on type. Their's is approx. 1" as a standard	The erosion shield is meant to protect the bottom flange of the adaptor which has a smaller bore than the casing housing. The erosion shield will be welded at the bottom of the 13 5/8" API 6A, 3000 psi flange.  The erosion shield should be 4" long weld on type.

#### ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the Clarification is an integral part of the document and the alterations set out in Clarification has been incorporated in the tender proposal.

**Signed** \_\_\_\_\_

**Tenderer** \_\_\_\_\_