



KENYA ELECTRICITY GENERATING COMPANY LIMITED

TENDER NO. KGN-GDD-064-2018

DATE: 6/07/2018

TENDER FOR SUPPLY OF STRATEGIC SPARES COOLING TOWER FILLS FOR OLKARIA II POWER STATION

CLARIFICATION NO.1:

In accordance with the tender mentioned above, KenGen hereby issues Clarification No. 1:

No.	Clarification	Response
1	Information about existing cooling towers:	The fill we require measures 72 inches with different widths as shown on the price schedule and technical specifications.
2	Water quality analysis:	
	a. Can you please provide the latest water quality analysis reports?	N/A
	b. Alternatively, please use the attached form	N/A
3	Why is the fill being replaced?	N/A
4	How long did the previous fill last?	N/A
5	In the technical specification, the flute angle is listed as 60° and 31°. We assume that 30° is correct.	Both are correct, kindly submit the angle with your offer for evaluation purposes
6	What will the fibreglass square tubes be used for?	For Structural Support on the C.T
7	What standard shall be used as the reference for “fire retardant” fibreglass?	Please refer to the detailed Technical Specifications No.9 in the tender
8	Shall the corrugated FRP louvers be made from fire retardant fibreglass?	Not Mandatory
9	Are there any countries of origin which are not acceptable?	No

10,11	Does a hardcopy of the tender need to be submitted or is electronic submission acceptable? If hardcopy is required, please confirm the address	Refer to the Tender Document - Att. Invitation to Tenderers (ITT)
12	Measurement of thermal performance	N/A

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the Clarification is an integral part of the document and has been incorporated in the tender document.

Signed

Tenderer:

Date:

