



KENYA ELECTRICITY GENERATING COMPANY LIMITED

**KG N-GOGO-03-2018
TENDER FOR SUPPLY, INSTALLATION AND COMMISSIONING OF 10T ELECTRIC HOIST AT
GOGO POWER STATION**

Date: 17th May, 2018

CLARIFICATION No. 1

In accordance with the KGN-GOGO-03-2018 Tender for Supply, Installation and Commissioning of 10T electric hoist at Gogo power Station, KenGen hereby issues **Clarification No. 1**.

No.	BIDDER'S QUESTION	KENGEN'S RESPONSE
1.	<p>From the site visit, Please confirm whether the following measurements are correct as advised by KenGen Representative on site. We seem to have made some errors when recording the measurements.</p> <ul style="list-style-type: none"> - The height of lift is 16feet - The long travel is 35meters - The cross travel span is 20meters - Please advise if the cross travel is on a single girder or double girder. - What width is 24 FT"? - If beam is strong enough to withstand 10tonnes. <p>A sketch illustration of these measurements will be of extra value.</p>	<p>It was clearly stated in the tender document that it was the duty of the bidders or their representative to take the measurements.</p> <ul style="list-style-type: none"> • The height of the lift as stated in tender document is minimum of 20m • Length is 23m • Width is 7m • It's a double girder. • The bidder was supposed to access the beam during the site visit. None the less the existing crane is 10t manual.

ACKNOWLEDGEMENT OF CLARIFICATION No.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date