



**TENDER NO. KGN-HYD (tana)-05-2017**

**DATE: 13/07/2017**

**KENYA ELECTRICITY GENERATING COMPANY**

**TENDER FOR SUPPLY INSTALLATION AND COMMISSIONING OF 400KVA DIESEL GENERATOR FOR TANA POWER STATION**

**CLARIFICATION No .2**

In accordance with the Tender for Supply Installation and Commissioning of 400KVA Diesel Generator for Tana Power Station, KenGen hereby issues Clarification No.2

**RESPONSE TO REQUEST FOR CLARIFICATION**

|  | <b>CLARIFICATION REQUEST FROM BIDDER</b>  | <b>KenGen RESPONSE</b>  |
|--|---|---|
|  | <p>We kindly wish to seek the below mentioned clarifications with respect to the above reference tender:</p> <p><b>1. Viz. Section VI Clause 7.0 (Cables):</b><br/>Kindly provide us with the measurements of cables intended to terminate at the Generator Panel</p> | <p><b>1. Section VI Clause 7.0 (Cables):</b></p> <p>The details of the power evacuation cable from the Diesel Generator to the 415 Switchboard shall be as follows:</p> <ul style="list-style-type: none"> <li>i. Single core XLPE Armored Copper Cable</li> <li>ii. Length 600 meters (150m per phase and Neutral)</li> <li>iii. 185mm<sup>2</sup> Cross Sectional Area</li> </ul> |
|  | <p><b>2. Viz. ITT Clause No. 6.3 (Mandatory Site Visit Form ):</b></p> <p>(a).Kindly provide us with a copy of the Mandatory Site Visit form for purposes of bidding.</p>   | <p>The list will be sent to all firms that visited the site via their respective email address, the list will be used as evidence of site visit and therefore should be attached to their bid document.</p>   |

**All other terms and conditions remain unchanged**

**ACKNOWLEDGEMENT OF CLARIFICATION NO. 2**

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....