



KENYA ELECTRICITY GENERATING COMPANY PLC.

KGN-GOGO-01-2019.

**TENDER FOR SUPPLY, INSTALLATION & COMMISSIONING OF 10T OVER HEAD
ELECTRIC CRANE AT GOGO POWER STATION.**

15th May, 2019.

ADDENDUM NO 1.

In Accordance with the Tender for “Supply, Installation & Commissioning Of 10T Over Head Electric Crane at Gogo Power Station.” KenGen hereby issues **Addendum No.1**

Additional information to the technical specifications.

1. Provided work way 700mm wide by 1000mm high guard rail.
2. The total maximum overall height of the crane should be less than 1400mm from the existing rail.

ACKNOWLEDGEMENT OF ADDENDUM NO 1.

We, the undersigned hereby certify that the Addendum is an integral part of the document and has been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....