



KENYA ELECTRICITY GENERATING COMPANY PLC

TENDER No. KGN-TURK-06-2019

SUPPLY AND DELIVERY OF 4 INCH CLASS B GALVANIZED STEEL PIPES AND ONE 300 CUBIC METER CAPACITY STEEL PLATE TANK TO TURKWEL POWER STATION

Date: 23rd April, 2019

CLARIFICATION No. 1 & ADDENDUM No.1

In accordance with the “Supply and Delivery of 4 Inch Class B Galvanized Steel Pipes and One 300 Cubic Meter Capacity Steel Plate Tank to Turkwel Power Station”, KenGen hereby issues **Clarification No. 1 & Addendum No.1**.

CLARIFICATION No. 1:

No	CLARIFICATION SOUGHT	KenGen RESPONSE
1	Regarding the 300cm steel tank are we supposed to do the assembly on site because from the tender document it's like its only supplying the tank panels. Then if we the supplier is to do the assembly on site has the foundation been done. Finally is it ground tank or elevated in which case a tower is required.	It is specified that the supply and delivery of the tank to be ground mounted by us. Please refer to the scope in section V item.
2	Kindly clarify whether the tank is ground mounted or elevated? If elevated, what is the height?	
3	Re: Letter of authority from the manufacturer. We are experiencing challenges /resistance from the hardware dealers concerning the issuance of the above letter of authorization. The tender requires multiple items which are to be sourced from different hardware stores making it difficult for them to give us the letter. Kindly advise us the way forward since this important document is mandatory in this tender. Kinds regards,--	The manufacturer's authorization letter is a mandatory requirement.
4	We the clients clarify whether the types of pipes requested are seamless or seam pipes, since seamless pipes accommodate higher pressures compared to seam pipes	Welded seam pipe that can withstand up to 10 bar pressure.

ADDENDUM No. 1:

The tender has been extended from **6th May 2019 at 2.00p.m** to **14th May, 2019 at 2.00 p.m.**

ACKNOWLEDGEMENT OF CLARIFICATION No.1 & ADDENDUM No.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....