



KENYA ELECTRICITY GENERATING COMPANY PLC

TENDER No. KGN- GOGO-01-2019

TENDER FOR SUPPLY, INSTALLATION & COMMISSIONING OF 10T OVER HEAD
ELECTRIC CRANE AT GOGO POWER STATION

Date: 24th April, 2019

CLARIFICATION No. 2

In accordance with the “Tender For Supply, Installation & Commissioning Of 10T Over Head Electric Crane at Gogo Power Station” KenGen hereby issues **Clarification No. 2**

	Inquiry	Clarification
1	Page no. 2 , Sr. No. 5, speeds : confusion due to 2 type of speeds are given for hoisting , trolley traversing, bridge traversing The speeds can be generally; (\pm 10%) <ul style="list-style-type: none">• Hoisting -0.4/3.5 m/min (Dual Speed)• Trolley Traversing- 6/20 m/min (Dual Speed)• Bridge Traverse -4/15 m/min (Dual Speed)	It should be dual speed as per the tender document.
2	There should be drawings so that in case any clarification the same can be submitted together	No drawings available. Measurements is as confirmed on site visit.

ACKNOWLEDGEMENT OF CLARIFICATION No.2

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....