



KENYA ELECTRICITY GENERATING COMPANY PLC

KGN-GDD-062-2019

TENDER FOR DESIGN, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF GEOTHERMAL WELLHEADS CONTROL CENTRE

Date: 9th May, 2019

CLARIFICATION No. 2

In accordance with the ‘Tender for Design, Supply, Installation, Testing and Commissioning of Geothermal Wellheads Control Centre’, KenGen hereby issues **Clarification No. 2**

No.	Bidders Question	KenGen’s response
1.	Kindly clarify on the following for vibration sensor quantity(40) shall it be : Qty (40) “ 20 for X axis and 20 for Y axis” or Qty (80) “40 for X axis and 40 for Y axis”	The quantity (40) is total for both X axis and Y axis. 20 for X axis and 20 for Y axis.

ACKNOWLEDGEMENT OF CLARIFICATION No. 2

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date