



KENYA ELECTRICITY GENERATING COMPANY PLC

Date: 11th June 2019

**KGN-GDD-106-2019
TENDER FOR SUPPLY OF COOLING TOWER SPARES FOR OLKARIA II POWER
STATION**

CLARIFICATION No. 1

In accordance with the **TENDER FOR SUPPLY OF COOLING TOWER SPARES FOR OLKARIA II POWER STATION**, KenGen hereby issues **Clarification No. 1**.

Item	BIDDERS REQUEST	KENGEN RESPONSE
1.	Amarillo Gear's shaft material is an Alloy Standard, does not contain Nickel. Their standard paint Finish is a 2 Part Epoxy Paint, not an Alkyd Paint.	The specifications given were erroneous as they were for a different product. Amarillo standard shaft material and paint schedule are acceptable.

ACKNOWLEDGEMENT OF CLARIFICATION No.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date