



ALL DIMENSIONS AND LEVELS ARE TO BE VERIFIED ON SITE BY THE CONTRACTOR BEFORE COMMENCING ANY WORK.

THE COPYRIGHT IN THIS DRAWING, INCLUDING THE DESIGN AND DETAILS SHOWN HEREON, IS RESERVED BY THE ENGINEERS.

THIS DRAWING IS NOT TO BE USED IN WHOLE OR PART OTHER THAN FOR THE INTENDED PURPOSE AND PROJECT AS DEFINED ON THIS DRAWING. REFER TO THE CONTRACT FOR FULL TERMS AND CONDITIONS.

ON ORIGINAL

- GENERAL NOTES:
- 1: ALL CONCRETE TO BE AS DIRECTED
  - 2: REINFORCEMENT TO BE HIGH YIELD AS DIRECTED
  - 3: MINIMUM COVER TO REINFORCEMENT TO BE: FOUNDATIONS = 50mm
  - 4: MINIMUM LAPS ARE 50 x DIAMETER OF THE BAR
  - 5: ALL FOUNDATIONS TO BE TAKEN DOWN TO FIRM BEARING STRATA TO ENGINEER'S APPROVAL
  - 6: ALL REINFORCEMENT TO BE INSPECTED BY THE STRUCTURAL ENGINEER BEFORE CONCRETING
  - 7: THE STRUCTURAL DRAWING TO BE READ IN CONJUNCTION WITH ARCHITECT & M.E. DRAWINGS

FIRM NAME AND ADDRESS	
PROJECT NAME AND ADDRESS	
CONNECTION OF MAKE UP WELLS OW-53B, OW-53C AND OW-53D AT OLKARIA GEOTHERMAL PROJECT	
DRAWING TITLE	
POND DETAILS LAYOUT SECTIONS AND ELEVATIONS	
DRAWING No.	
OW-53-SFD-EB-DRG-038	
Date	24/03/2019
Scale	1:150